

Instructions

Kit Part Number: 123034

Description: Instr. Kit CNG Priority Panel Control Installation

Parts Included:

- (1) 119910 Programmed EPROM U25 LNG/CNG
- (1) 119911 Programmed EPROM U30 LNG/CNG

Instructions:

WARNING: Follow all requirements in CNG Installation Manual for proper installation.

1. Power dispenser off.
2. Remove old software (Programmed EPROM) from U25 and U30 on the CPU board.
3. Software Revision Level must be 29 or higher.
4. Install new software (Programmed EPROM) included in the kit into U25 and U30 on the CPU board.
5. Use only 14 gage stranded gas and oil resistance THHN wire.
6. Run one 14 gage wire per side of dispenser from the priority panel control in conduit.
7. Check with Federal, State and Local Codes for conduit use in your area. Bennett recommends rigid metal conduit.
8. Side 1 connects to TS2 pin 7 on the Power Distribution board.
9. Side 2 connects to TS2 pin 11 on the Power Distribution board.
10. Conduit must be potted according to installation manual.

