

NOTE: ALL PIPE JOINTS TO BE SEALED WITH UL LISTED COMPOUND.

1. SEPERATE SEE GAGE.
2. ATTACH PART OF SEE GAGE WITH THE GLASS TO THE OUTLET USING THE NIPPLE AND REDUCER PROVIDED, AND TIGHTEN JOINT PLACING WRENCH AT JOINT.
3. ATTACH NUT PORTION OF SEE GAGE TO THE HOSE AND TIGHTEN JOINT.
4. REATTACH NUT TO THE SEE GAGE. DO NOT USE PIPE SEALANT. TIGHTEN JOINT TO PREVENT ACCIDENTIAL LOOSENING.

